


THIRD ANGLE PROJECTION
ALL DIMENSIONS IN mm UNLESS STATED


Scale: **Not To Scale** Size: **A3**

- Notes:**
1. MAXIMUM CABLE LUG SIZE FOR MAINS INPUT AND LOAD OUTPUT TERMINALS = 50mm² (M6 LUG).
 2. MAXIMUM CABLE SIZE FOR UPS INPUT AND UPS OUTPUT TERMINALS = 50mm² (M6 LUG)
 3. MAXIMUM CABLE SIZE FOR AUXILIARY CONTACTS = 4mm².
 4. GLAND ENTRY AT REAR.
 5. PANEL COLOUR = BLACK.


TOP VIEW



REAR VIEW



FRONT VIEW



00	22/08/16	FIRST ISSUE	C.B
			P.J
Rev	Date	Description	Dr'n Ck'd



Adept Power Solutions

Unit 1, Viscount Court
Walworth Industrial Estate, South Way
Andover, Hampshire. SP10 5NW
Tel: +44 (0) 1264 351217 Fax: +44 (0) 1264 351217

Project:
STANDARD PRODUCT

Drawing Title:
**RACK MOUNTED UPS
EXTERNAL MAINTENANCE
BYPASS PANEL (TYPE 2)
SINGLE PHASE IN
SINGLE PHASE OUT
RATING - 32A**

Drawn By: **C.B** Date: **28/01/2019**

Checked By: **P.J** Date: **28/01/2019**

Drawing Number:
APS-BP-0327-00