





TOP VIEW



REAR VIEW



FRONT VIEW



THIRD ANGLE PROJECTION
ALL DIMENSIONS IN mm UNLESS STATED

Scale:
Not To Scale

Size:
A3

Notes:

1. MAXIMUM CABLE LUG SIZE FOR MAINS INPUT TERMINALS = 50mm² (M6 LUG).
2. MAXIMUM CABLE SIZE FOR UPS INPUT AND UPS OUTPUT TERMINALS = 50mm² (M6 LUG)
3. MAXIMUM CABLE SIZE FOR AUXILIARY CONTACTS = 4mm².
4. GLAND ENTRY AT REAR.
5. PANEL COLOUR = BLACK.
6. LOAD OUTPUT VIA IEC CONNECTORS.

00	04/07/19	FIRST ISSUE	C.B
			P.J
Rev	Date	Description	Dr'n
			Ck'd



Adept Power Solutions

Unit 1, Viscount Court
Walworth Industrial Estate, South Way
Andover, Hampshire. SP10 5NW
Tel: +44 (0) 1264 351217 Fax: +44 (0) 1264 351217

Project:

STANDARD PRODUCT

Drawing Title:

**RACK MOUNTED UPS
EXTERNAL MAINTENANCE
BYPASS PANEL (TYPE 2)
SINGLE PHASE IN
SINGLE PHASE OUT
RATING - 63A & 80A IEC**

Drawn By:
C.B Date:
04/07/2019

Checked By:
P.J Date:
04/07/2019

Drawing Number:
APS-BP-0330-00